







Powering a worl in progress









# Social Welfare Report 01-04 / 2013

#### January 2013



Additional Social welfare that could be gained with no network constraints:

14,7 M€


Social welfare = Producer surplus + Consumer surplus + Congestion rent

Producer surplus	60 M€
Consumer surplus	-13,6 M€
Congestion Rent	-31,7 M€

<u>NB</u>: Producer surplus, Consumer surplus and Congestion Rent are calculated as such: Sum of daily (Value with ATC= $\infty$ ) - (Historical value) The daily values being a Sum of hourly values.

#### January 2013





#### February 2013



Additional Social welfare that could be gained with no network constraints:

14,7 M€


Social welfare = Producer surplus + Consumer surplus + Congestion rent

Producer surplus	76 M€
Consumer surplus	-30,3 M€
Congestion Rent	-31 M€

<u>NB</u>: Producer surplus, Consumer surplus and Congestion Rent are calculated as such: Sum of daily (Value with ATC= $\infty$ ) - (Historical value) The daily values being a Sum of hourly values.

#### February 2013





#### **March 2013**



Additional Social welfare that could be gained with no network constraints:

38,8 M€


Social welfare = Producer surplus + Consumer surplus + Congestion rent

Producer surplus	199,7 M€
Consumer surplus	-97,5 M€
Congestion Rent	-63,9 M€

<u>NB</u>: Producer surplus, Consumer surplus and Congestion Rent are calculated as such: Sum of daily (Value with ATC= $\infty$ ) - (Historical value) The daily values being a Sum of hourly values.

#### **March 2013**





#### **April 2013**



Additional Social welfare that could be gained with no network constraints:

27,6 M€


Social welfare = Producer surplus + Consumer surplus + Congestion rent

Producer surplus	109,0 M€
Consumer surplus	-27,7 M€
Congestion Rent	-53,7 M€

<u>NB</u>: Producer surplus, Consumer surplus and Congestion Rent are calculated as such: Sum of daily (Value with ATC= $\infty$ ) - (Historical value) The daily values being a Sum of hourly values.

#### **April 2013**







Definitions / explanations

### Additional Social welfare that could be gained with no network constraints (<u>Definition/explanation</u>)



- ▶ The figure shows the additional social welfare that could be gained with no network constraints inside CWE (borders D-NL, NL-B, B-F, D-F).
- This key figure is calculated by hourly simulating/ coupling the CWE-region with ATC= ∞ at the borders D-NL, NL-B, B-F, D-F and comparing to real MC-results:
  - Producer surplus = Producer surplus (ATC= ∞)- Producer surplus (real ATC)
  - Consumer surplus=Consumer surplus (ATC= ∞)- Consumer surplus(real ATC)
  - Congestion rent= Congestion rent (ATC= ∞)- congestion rent(real ATC)
- NB: The simulations are made with ITVC flows remaining identical.

### Additional Social welfare that could be gained with no network constraints (<u>Definition/explanation</u>)




- The purpose of the welfare reporting is the demonstration of the benefits of CWE ATC Market Coupling and future CWE FB MC.
- The monthly publishing of this figure was commonly agreed between the CWE Regulators and the CWE Project. It is one part of the welfare reporting.




Examples: "In single hours the producer/consumer gain can be positive or negative"

### Decrease in consumer surplus example 1/2 Two isolated markets (zero capacity)







Area 1

MCV: 1000 MW, MCP: € 10

Consumer surplus: € 60K

Producer surplus: € 0

Area 2

MCV: 500 MW, MCP: € 50

Consumer surplus: € 0

Producer surplus: € 10K

**Totals** 

Consumer surplus: € 60K


Producer surplus: € 10K

Congestion revenue: € 0

Social welfare: € 70K

## Decrease in consumer surplus example 2/2 Two coupled markets (infinite capacity)





Area 1

MCV: 1400 MW, MCP: € 50

Consumer surplus: € 20K Producer surplus: € 56K Area 2

MCV: 500 MW, MCP: € 50

Consumer surplus: € 0 Producer surplus: € 10K


**Totals** 

Consumer surplus: € 20K (-40K) Congestion revenue: € 0

Producer surplus: € 66K (+56K) Social welfare: € 86K (+16K)

## Decrease in producer surplus example 1/2 Two isolated markets (zero capacity)





70 60 50 consumer 40 surplus (2) 30 20 10 0 2000 0 500 1000 1500 Demand ——Supply

Area 1

MCV: 1000 MW, MCP: € 70

Consumer surplus: € 0 Producer surplus: € 60K

Area 2

80

MCV: 500 MW, MCP: € 30

Consumer surplus: € 10K

Producer surplus: € 0

#### **Totals**

Consumer surplus: € 10K Con


Producer surplus: € 60K

Congestion revenue: € 0

Social welfare: € 70K

# Decrease in producer surplus example 2/2 Two coupled markets (infinite capacity)





Area 1

MCV: 1400 MW, MCP: € 30

Consumer surplus: € 56K Producer surplus: € 20K Area 2

MCV: 500 MW, MCP: € 30

Consumer surplus: € 10K

Producer surplus: € 0

**Totals** 

Consumer surplus: € 66K (+56K) Congestion revenue: € 0

Producer surplus: € 20K (-40K) Social welfare: € 86K (+16K)